



Meetings,

My name is Michael LeBrun. I have been the General Manager of Nipomo Community Services District since September, 2004. I have lived on the Nipomo Mesa since 1994 and I am happy to have the opportunity to work in my community.

The data included in this mailer is forwarded to all customers annually to give assurance your water supply is safe. This report contains plenty of tables and information. The upshot is - the District continues to supply safe, high-quality drinking water.

As the General Manager, I direct all aspects of your service district's day to day operation, providing clean, safe water, efficient wastewater collection, and solid waste services. I am given policy direction by the District's Board of Directors - a five-member board that is elected by you, the residents of this District.

NCS D Board of Directors:

- Larry Vierheilig President
- Ed Eby Vice President
- Mike Winn Director
- Judith Wirsing Director
- Cliff Trotter Director

The Board and I invite you to become informed and involved with the numerous issues facing the District. Regular Board meetings are held the 2nd and 4th Wednesday of each month. Agendas and minutes are posted on our website ("Nipomocsd.com"). Additionally, a complete audio recording of meetings is available upon request.

At our website you can sign up to receive email notification of various District actions (posting of agendas and minutes; new reports and studies, etc.) - see "Sign Up For Notification."

CONSERVATION REMINDERS

Finally, a reminder about water use and some facts and figures:

Summer is around the corner and our average customer sees a 100% increase in water use during the summer. This leads to some large water bills and puts serious demand on our water system.

Do what you can to conserve water and save yourself some money:

- Check your irrigation system for leaks and proper operation prior to returning it to summer service mode.
- Use a broom in place of a hose to clean surfaces.
- Using water-saving appliances washing machines, dishwashers, toilets, and fixtures in your home can reduce your use and bill by approximately 30%. When electric costs are considered, energy/water-efficient appliances save even more.



Enjoy your summer and this beautiful place we are so fortunate to call home.

Yours in service,

Michael LeBrun



Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care provider. EPA/CDC guidelines on appropriate means to lessen the risk of infection by Cryptosporidium and other microbial contaminants are available from the Safe Drinking Water Hotline 1 (800-426-4791).

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the EPA's Safe Drinking Water Hotline 1 (800-426-4791).

In order to ensure that tap water is safe to drink, USEPA and the California Department of Health Services (Department) prescribe regulations which limit the amount of certain contaminants in water provided by public water systems. Department regulations also establish limits for contaminants in bottled water that must provide the same protection for public health.

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

Contaminants that may be present in source water include:

- **Microbial contaminants,** such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations and wildlife.
- **Inorganic contaminants,** such as salts and metals, which can be naturally-occurring or result from urban stormwater runoff, industrial or domestic wastewater discharges, oil and gas production, mining or farming.
- **Pesticides and herbicides,** which may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses.
- **Radioactive contaminants,** which can be naturally occurring or the result of oil production and mining activities.
- **Organic chemical contaminants,** including synthetic and volatile organic chemicals, which are byproducts of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff, and septic systems.

This brochure is a snapshot of the quality of the water that we provided last year. Included are details about where your water comes from, what it contains, and how it compares to State standards. We are committed to providing you with this information to keep you informed about your water supply.

For more information about your water, you may call (805) 929-1133 and ask for Michael LeBrun. Public meetings are held the second and fourth Wednesday of each month at 9:00 a.m. at 148 South Wilson Street in Nipomo, California. Meeting agendas and breaking District news can be accessed on the District's website at nipomocsd.com.

Este informe contiene información muy importante sobre su agua beber. Traduzcalo a hablé con alguien que lo entienda bien.

Your water comes from 2 distinct groundwater sources: the Nipomo Mesa Sub-Basin, and the Nipomo Valley Basin via eight wells.

An assessment of the drinking water sources was completed in May and June of 2001. These sources are considered most vulnerable to the following activities associated with contaminants detected in the water supply: Historic Gas Stations, Septic Systems-Low and High Density, Sewer Collection Systems-Low and High Density, Sewer Collection Systems and Wastewater Treatment Plants. A copy of the complete assessment may be viewed at the District office.

Nipomo Community Services District - Town Division
CONSUMER CONFIDENCE REPORT - 2004
WATER QUALITY DATA

The table below lists all the drinking water contaminants that we detected during the 2004 calendar year. The presence of these contaminants in the water does not necessarily indicate that the water poses a health risk. Unless otherwise noted, the data presented in this table is from testing done January 1 - December 31, 2004. The State requires us to monitor for certain contaminants less than once per year because the concentrations of those contaminants are not expected to vary significantly from year to year. Some of the data, though representative of the water quality, is more than one year old.

Terms & abbreviations used below:

- ◆ **Public Health Goal (PHG):** The level of a contaminant in drinking water below which there is no known or expected risk to health. PHGs are set by the California Environmental Protection Agency.
- ◆ **Maximum Contaminant Level Goal (MCLG):** The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are set by the U.S. Environmental Protection Agency.
- ◆ **Maximum Contaminant Level (MCL):** The highest level of a contaminant that is allowed in drinking water. Primary MCLs are set as close to the PHGs (or MCLGs) as is economically and technologically feasible. Secondary MCLs are set to protect the odor, taste, and appearance of drinking water.
- ◆ **Maximum Residual Disinfectant Level (MRDL):** The level of a disinfectant added for water treatment that may not be exceeded at the consumer's tap.
- ◆ **Maximum Residual Disinfectant Level Goal (MRDLG):** The level of a disinfectant added for water treatment below which there is no known or expected risk to health. MRDLs are set the U.S. Environmental Protection Agency.
- ◆ **Regulatory Action Level (AL):** The concentration of a contaminant, which, if exceeded, triggers treatment or other requirements that a water system must follow.
- ◆ **Primary Drinking Water Standards (PDWS):** MCLs and MRDLs for contaminants that affect health along with their monitoring and reporting requirements, and water treatment requirements.
- ◆ **Secondary Drinking Water Standards (SDWS):** MCLs for contaminants that affect taste, order, or appearance of the drinking water. Contaminants with SDWSs do not affect the health at the MCL levels.
- ◆ **n/a:** not applicable **ND:** not detectable at testing limit **NS:** no standard or not regulated **MFL:** million fibers per liter
- ◆ **NTU:** Nephelometric Turbidity Units **pCi/L:** picocuries per liter (a measure of radiation) **ppb:** parts per billion or micrograms per liter ($\mu\text{g/L}$) **ppm:** parts per million or milligrams per liter (mg/L) **ppq:** parts per quadrillion or picograms per liter (pg/L) **ppt:** parts per trillion or nanograms per liter (ng/L)

Lead and Copper Rule							
Detected Contaminants	Units	No. of Samples Collected	No. Sites Exceeding AL	90 th Percentile Level	AL	PHG	Typical Sources of Contaminants
Lead (Pb)	ppb	19 (2003)	0	2.50	15	2	Internal corrosion of household water plumbing systems; discharges from industrial manufacturers, erosion of natural deposits
Copper	ppm	19 (2003)	0	0.522	1	0.17	Internal corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives

Primary Drinking Water Standards (PDWS)						
Detected Contaminants	Units	MCL	PHG (MCLG)	Results Average Range		Typical Sources of Contaminants
Arsenic (As)	ppb	50	n/a	2.2	ND - 8.0 (2002-2004)	Erosion of natural deposits; runoff from orchards, glass and electronics production wastes
Barium (Ba)	ppm	1	2	0.0315	0.0161 - 0.0453 (2002-2004)	Discharge from oil drilling wastes and from metal refineries; erosion of natural deposits
Cadmium (Cd)	ppb	5.0	0.07	0.30	ND - 0.9 (2002-2004)	Internal corrosion of galvanized pipes; erosion of natural deposits; discharge from electroplating and industrial chemical factories, and from metal refineries; runoff from waste batteries and paints
Chromium (Total Cr)	ppb	50.0		ND	ND - 2 (2002-2004)	Discharge from steel and pulp mills and chrome plating; erosion of natural deposits
Fluoride (F)	ppm	2	1	0.10	ND - 0.2 (2002-2004)	Erosion of natural deposits; water additive that promotes strong teeth; discharge from fertilizer and aluminum factories.
Mercury	ppb	2	1.2	ND	ND - 0.04 (2002-2004)	Discharge from steel and pulp mills and chrome plating; erosion of natural deposits
Nickel	ppb	100	12	ND	ND - 1 (2002-2004)	Erosion of natural deposits; discharge from metal factories
Nitrate (NO3)	ppm	45	45	4.74	ND - 14.5 (2002-2004)	Runoff and leaching from fertilizer use; leaching from septic tanks and sewage; erosion of natural deposits
Selenium (Se)	ppb	50		ND	ND - 3 (2002-2004)	Discharge from petroleum, glass, and metal refineries; erosion of natural deposits; discharge from mines and chemical manufacturers; runoff from livestock lots (feed additive)

Nipomo Community Services District - Town Division

CONSUMER CONFIDENCE REPORT - 2004

Detected Contaminants	Units	MCL	PHG (MCLG)	Results		Typical Sources of Contaminants
				Average	Range	
Radioactivity Gross Alpha	pCi/L	15		3.28	ND - 9.27 (2000-2004)	Erosion of natural deposits
Gross Beta	pCi/L	50		0.394	(2004-2004)	Decay of natural and man-made deposits
Uranium	pCi/L	20	0.5	3.75	0.11 - 5.37 (2004-2004)	Erosion of natural deposits
Organic Total Trihalomethanes (TTHMs)	ppb	80		0.97	ND - 4.9 (2002-2004)	By-product of drinking water chlorination

Secondary Drinking Water Standards (SDWS)						
Detected Contaminants	Units	MCL	PHG (MCLG)	Results		Typical Sources of Contaminants
				Average	Range	
Inorganic Chloride	ppm	500		77.3	42-143 (2000-2004)	Runoff/leaching from natural deposits; seawater influence
Color (Unfiltered)	Units	15		ND	ND - 7 (2002-2004)	Naturally-occurring organic materials
Corrosivity (Langlier Index)		> 0		-0.6	-2 - 0.1 (2002-2004)	Natural or industrial-influenced balance of hydrogen, carbon and oxygen in the water; affected by temperature and other factors
Iron (Fe)	ppb	300		51	ND - 170 (2002-2004)	Leaching from natural deposits; Industrial wastes
Manganese (Mn)	ppb	50		ND	ND - 20 (2002-2004)	Leaching from natural deposits
Specific Conductance	umhos /cm	1600		851	342-1440 (2002-2004)	Substances that form ions when in water; seawater influence
Sulfate (SO4)	ppm	500		182	6 - 310 (2000-2004)	Runoff/leaching from natural deposits; industrial wastes
TDS	ppm	1000		583	210 - 910 (2002-2004)	Runoff/leaching from natural deposits
Turbidity	NTU	5		ND	ND - 0.5 (2002-2004)	Soil runoff

Unregulated Contaminants						
Detected Contaminants	Units	MCL	PHG (MCLG)	Results		Typical Sources of Contaminants
				Average	Range	
Inorganic Boron	ppm	NS		0.060	ND - 0.13 (2000-2004)	Some men who drink water containing boron in excess of action level over many years may experience reproductive effects, based on studies in dogs.
Chromium VI (Hexavalent Chromium)	ppb	NS		0.74	ND - 2.2 (2003-2003)	N/A
Sodium	ppm	NS		68.3	36 - 112 (2000-2004)	Sodium refers to the salt present in the water and is generally naturally occurring.
Total Hardness (as CaCO3)	ppm	NS		298	70 - 553 (2002-2004)	Hardness is the sum of polyvalent cations present in the water, generally magnesium and calcium. The cations are usually naturally occurring.
Vanadium	ppm	NS		0.0057	ND - 0.012 (2003-2004)	The babies of some pregnant women who drink water containing vanadium in excess of action level may have an increased risk of developmental effects, based on studies in laboratory animals.
Organic Bromoform	ppb	NS		0.83	ND - 3.7 (2002-2004)	N/A
Dibromochloromethane	ppb	NS		ND	ND - 1.2 (2002-2004)	N/A

Item(s) shaded are greater than MCL or AL. Additional information regarding the violation is provided below.

Additional Information and Explanations

About our Langlier Index: Corrosivity less than 0 indicates your water may be corrosive to the plumbing and fixtures. The Corrosivity MCL was set to protect you against unpleasant aesthetic affects such as color, taste and odor. Violating this MCL does not pose a risk to public health.

Compliance with Other Regulations

The State requires us to test our water on a regular basis to ensure its safety. In the previous year, we met all sampling, treatment and reporting requirements.